



**CCRL**  
Cement and Concrete  
Reference Laboratory

[www.ccrl.us](http://www.ccrl.us)

July 13, 2017

Mr. Scott Seiter  
Division Engineer  
Oklahoma Department of Transportation  
200 Northeast 21<sup>st</sup> Street  
Oklahoma City, Oklahoma 73105

Subject: Inspection of Cement, Pozzolan, and Concrete Testing Laboratories

Dear Mr. Seiter:

Enclosed is a confirmatory report on Inspection Number W-1166, which was completed in your testing laboratories at Oklahoma City, Oklahoma, on May 18, 2017, by a representative of the Cement and Concrete Reference Laboratory.

This letter, and the accompanying report, provide written evidence that your laboratories have been inspected during the 37<sup>th</sup> Inspection Tour.

Very truly yours,

Jan A. Prowell  
Director  
Cement and Concrete Reference Laboratory

Enclosure

cc: D. McCullough  
J. Thomas  
Division Administrator, FHWA



## Inspection Report Introduction

This report covers the cement, pozzolan, and concrete inspection conducted in the laboratories of Oklahoma Department of Transportation, at Oklahoma City, Oklahoma. This inspection, designated as Inspection Number W-1166, was completed in the laboratories on May 18, 2017.

Inspections generally cover three areas: quality systems; testing equipment; and procedures. Under all material types inspected there will be a Summary of Findings and a Footnote Section. The Summary of Findings will denote items examined, which may include: documents, equipment and procedures performed by the laboratory. Entries in the Summary of Finding Section cover availability, physical condition, and/or conformance to specification requirements. These items, when checked, will indicate whether the items conformed to the ASTM standard or will state briefly any deviation from the standard and will be listed in the Footnote Section. The Footnote Section is also used to convey observations, recommendations or explanations of conditions found. When a footnote of this nature appears in a report it is labeled as an "Informational Footnote" in bold font. These informational footnotes do not require deficiency corrections.

Corrections of minor deficiencies are encouraged during the course of each inspection. In the interest of brevity, any adjustments of this nature which may have been made have not been mentioned in the report.

Several pieces of apparatus in the laboratory have been assigned CCRL identification numbers. Some of these numbers are listed in the Summary and Footnote Sections.

For a more in-depth description of the scope of each inspection, please see [www.ccrl.us/Lip/lip.htm](http://www.ccrl.us/Lip/lip.htm). The inspection was conducted using the most recent version of the applicable Book of ASTM Standards available at the time of the inspection, unless otherwise indicated in the Footnote Section of this report.

This report confirms the condition of the laboratory on the inspection date noted above. It does not approve, certify or accredit this laboratory; therefore, publicizing the inspection without offering a review of this report is prohibited.

## CEMENT SUMMARY OF FINDINGS

### Quality System

<u>Inspection Item</u>	<u>Status</u>
<u>Quality System C1222-13</u>	
• Organization .....	<u>Satisfactory</u>
• Human Resources	
· Director of Testing .....	<u>Satisfactory</u>
· Training .....	<u>Satisfactory</u>
· Performance Evaluation .....	<u>Satisfactory</u>
· Personnel Records .....	<u>Satisfactory</u>
• Operations	
· Standard Operating Procedures .....	<u>Satisfactory</u>
· Final Report .....	<u>Satisfactory</u>
• Quality	
· Technical Complaints .....	<u>Satisfactory</u>
· External Technical Services .....	<u>Satisfactory</u>
· Proficiency Sample Testing .....	<u>Satisfactory</u>
· Standard Test Methods .....	<u>Satisfactory</u>
· Internal Quality System Review .....	<u>Satisfactory</u>
• Equipment	
· Inventory .....	<u>Satisfactory</u>
· Equipment Calibration .....	<u>Satisfactory</u>
· Records .....	<u>Satisfactory</u>
· Calibration Procedures .....	<u>Satisfactory</u>

Qualification of Chemical Analysis C114-15

• Frequency .....	<u>Satisfactory</u>
• Records:	

<u>Analyte</u>	<u>Method</u>	<u>*Qualified</u>
Silicon Dioxide .....	X-Ray .....	<u>See footnote (a)</u>
Aluminum Oxide .....	X-Ray .....	<u>Yes</u>
Ferric Oxide .....	X-Ray .....	<u>Yes</u>
Calcium Oxide .....	X-Ray .....	<u>See footnote (a)</u>
Magnesium Oxide .....	X-Ray .....	<u>Yes</u>
Sulfur Trioxide .....	X-Ray and Reference .....	<u>Yes</u>
Loss on Ignition .....	Reference .....	<u>Yes</u>
Sodium Oxide .....	X-Ray .....	<u>See footnote (a)</u>
Potassium Oxide .....	X-Ray .....	<u>Yes</u>
Titanium Dioxide .....	X-Ray .....	<u>Yes</u>
Phosphorus Pentoxide .....	X-Ray .....	<u>Yes</u>
Zinc Oxide .....	X-Ray .....	<u>Yes</u>
Manganic Oxide .....	X-Ray .....	<u>Yes</u>
Insoluble Residue .....	Reference .....	<u>Yes</u>

\*Entry covers conformance to permissible variations in data results as listed in Table 1 of C114.

**Apparatus**

<u>Inspection Item</u>	<u>Status</u>
<u>Storage Facilities for Test Specimens C511-13</u>	
• Moist Air Storage Facilities .....	<u>See footnote (b)</u>
• Water Storage Facilities .....	<u>See footnote (b)</u>
<u>Density C188-15</u>	
• Density Equipment .....	<u>Satisfactory</u>
• Accessory Apparatus .....	<u>Satisfactory</u>
<u>Loss on Ignition C114-15</u>	
• Crucible .....	<u>Satisfactory</u>
• Muffle Furnace .....	<u>Satisfactory</u>
• Miscellaneous .....	<u>Satisfactory</u>
<u>Wet Sieving Apparatus C430-08</u>	
• 45-µm (No. 325) Sieve(s) .....	<u>Satisfactory</u>
• Accessory Apparatus .....	<u>Satisfactory</u>
<u>Autoclave Soundness Apparatus C151-15 and C490-11</u>	
• Autoclave(s):	
• Maker: <u>Boekel</u> Serial Number: <u>1011-24</u> .....	<u>Satisfactory</u>
• Length Comparator(s) .....	<u>Satisfactory</u>
Number Checked: <u>1</u> .....	
• Bar Mold(s) .....	<u>Satisfactory</u>
Number Checked: <u>3</u> .....	
<u>Graduates C1005-10</u>	
• Capacity: <u>250 mL</u> CCRL Number: <u>R-1761</u> .....	<u>Satisfactory</u>
<u>Flow Table C230-14</u>	
• Flow Table(s):	
• Maker: <u>Humboldt</u> .....	<u>Satisfactory</u>
• Accessory Apparatus .....	<u>Satisfactory</u>
<u>Compression Test Apparatus C109-16a and E4-16</u>	
• Compression Testing Machine:	
• Maker: <u>Tinius Olsen</u>	
• Serial Number: <u>222424</u> Capacity: <u>60,000 lbf</u>	
• Accuracy of Indication:	
• Range: <u>60,000 lbf</u> From: <u>5,000</u> to <u>36,000 lbf</u> ..	<u>Satisfactory</u>
• Mechanical Condition .....	<u>Satisfactory</u>
• Design .....	<u>Satisfactory</u>
• Verification Records .....	<u>Satisfactory</u>
• Bearing Blocks .....	<u>Satisfactory</u>
• Cube Molds: Number Checked: <u>12</u> .....	<u>Satisfactory</u>
• Tampers .....	<u>Satisfactory</u>
<u>Mix Balance(s) C1005-10</u>	
• Maker: <u>Mettler Toledo</u>	
Capacity: <u>3,100 g</u> CCRL Number: <u>M-1142</u> .....	<u>Satisfactory</u>
<u>Vicat Apparatus C187-11, C191-13, and C451-13</u>	
• Vicat Apparatus(es):	
• CCRL Number: <u>P-280</u> .....	<u>Satisfactory</u>
• CCRL Number: <u>U-2450</u> .....	<u>Satisfactory</u>
• Vicat Rings: Number Checked: <u>5</u> .....	<u>Satisfactory</u>

<u>Inspection Item</u>	<u>Status</u>
<u>Gillmore Needles C266-15</u>	
• Initial Needles:	• Final Needles:
• CCRL Number: <u>T-3001</u>	• CCRL Number: <u>W-3334</u> . . . .
• Mountings: . . . . .	<u>Satisfactory</u>
	<u>Satisfactory</u>
<u>Mechanical Mixing Apparatus C305-14</u>	
• Mixer(s):	
• Maker: <u>Hobart</u> Serial Number: <u>31-1391-318</u> .	<u>Satisfactory</u>
• Accessory Apparatus: . . . . .	<u>Satisfactory</u>
<u>Air Content Apparatus C185-15a</u>	
• 400 mL Measure(s) . . . . .	<u>Satisfactory</u>
• Accessory Apparatus . . . . .	<u>Satisfactory</u>
<u>Air Permeability Apparatus C204-16</u>	
• Blaine Meter(s):	
• CCRL Number: <u>K-1620</u> . . . . .	<u>Satisfactory</u>
• Accessory Apparatus . . . . .	<u>Satisfactory</u>
<u>Standard Sands C778-13 and E11-16</u>	
• Sand Verification . . . . .	<u>Satisfactory</u>
• Sample Splitter . . . . .	<u>Satisfactory</u>
• Sieves . . . . .	<u>Satisfactory</u>
<u>Miscellaneous</u>	
• Temperature of Air in Laboratory . . . . .	<u>Satisfactory</u>
• Relative Humidity of Air in Laboratory . . . . .	<u>Satisfactory</u>
• Temperature of Mixing Water . . . . .	<u>Satisfactory</u>
• Miscellaneous Accessory Testing Apparatus . . . . .	<u>Satisfactory</u>

**Procedures**

<u>Test</u>	<u>Method Reference</u>	<u>Technique in Exact Agreement With Standard Practice</u>
Normal Consistency Test . . . . .	C187-11 and C305-14 . . . . .	<u>Yes</u>
Vicat Time of Set Test (Method A) . . . . .	C191-13 and C305-14 . . . . .	<u>Yes</u>
Preparation of:		
Gillmore Pat . . . . .	C266-15 and C305-14 . . . . .	<u>Yes</u>
Autoclave Bars . . . . .	C151-15 and C305-14 . . . . .	<u>Yes</u>
Mortar Cubes . . . . .	C109-16a, C305-14, and C1437-15 . . . . .	<u>Yes</u>
Testing of Autoclave Bars . . . . .	C151-15 . . . . .	<u>Yes</u>
Testing of Mortar Cubes . . . . .	C109-16a . . . . .	<u>Yes</u>
Air Content Determination . . . . .	C185-15a and C305-14 . . . . .	<u>Yes</u>
No. 325 Sieve Fineness Test . . . . .	C430-08 . . . . .	<u>Yes</u>
Loss on Ignition . . . . .	C114-15 . . . . .	<u>Yes</u>
Density . . . . .	C188-15 . . . . .	<u>Yes</u>
Air Permeability Fineness Test . . . . .	C204-16 . . . . .	<u>Yes</u>
Handling of Samples . . . . .	C183-15 . . . . .	<u>Yes</u>

## CEMENT FOOTNOTE SECTION

Qualification of Chemical Analysis (C114-15):

(a) Records: Seven Certified Reference Materials (CRMs) were used when performing qualification testing for silicon dioxide, calcium oxide, and sodium oxide. Duplicate tests for sodium oxide did not meet the criteria that at least six of the seven differences between duplicates shall not exceed the limits in Column 2 of Table 1 of C114 and all data shall differ by no more than twice that value as required by Section 5.4.2.2 of C114. Also, when data from the average of duplicate tests for silicon dioxide, calcium oxide, and sodium oxide were compared to the certified concentrations, these analytes did not meet the criteria that at least six of the seven averages for each analyte shall not differ from the limits in Column 3 of Table 1 of C114 and all data shall differ by no more than twice that value as required by Section 5.4.2.3 of C114.

Curing Facilities (C511-13):

(b) The temperature of the moist storage air and the temperature of the storage water tanks were observed at intervals on May 11, 2017 and found to be as follows:

<u>Time:</u>	<u>Moist Storage Air:</u>	<u>Water Storage #1:</u>	<u>Water Storage #2:</u>	<u>Water Storage #3:</u>
8:30 a.m.	20.8°C	20.6°C	20.6°C	20.3°C
12:00 p.m.	21.0°C	20.1°C	20.1°C	20.0°C
4:00 p.m.	20.6°C	20.3°C	20.3°C	20.1°C

The range specified in C511 is 21.0 to 25.0°C.

## POZZOLAN SUMMARY OF FINDINGS

### *Apparatus*

<u>Inspection Item</u>	<u>Status</u>	
<u>Qualification of Chemical Analysis C114-15 and C311-13</u>		
• Frequency .....	<u>Satisfactory</u>	
• Records:		
<u>Analyte</u>	<u>Method</u>	
<u>*Qualified</u>		
Silicon Dioxide .....	X-Ray .....	<u>See footnote (a)</u>
Aluminum Oxide .....	X-Ray .....	<u>Yes</u>
Ferric Oxide .....	X-Ray .....	<u>Yes</u>
Calcium Oxide .....	X-Ray .....	<u>See footnote (a)</u>
Magnesium Oxide .....	X-Ray .....	<u>Yes</u>
Sulfur Trioxide .....	X-Ray and Reference .....	<u>Yes</u>
Loss on Ignition .....	Reference .....	<u>Yes</u>
Sodium Oxide .....	X-Ray .....	<u>See footnote (a)</u>
Potassium Oxide .....	X-Ray .....	<u>Yes</u>
*Entry covers conformance to permissible variations in data results as listed in Table 1 of C114.		
<u>Storage Facilities for Test Specimens C511-13</u>		
• Moist Air Storage Facilities .....	<u>See footnote (b)</u>	
• Water Storage Facilities .....	<u>See footnote (b)</u>	
<u>Sieves C441-11 and E11-16</u> .....	<u>Satisfactory</u>	
<u>Wet Sieving Apparatus C311-13 and C430-08</u>		
• 45-µm (No. 325) Sieve(s) .....	<u>Satisfactory</u>	
• Accessory Apparatus .....	<u>Satisfactory</u>	
<u>Autoclave Soundness Apparatus C151-15 and C490-11</u>		
• Autoclave(s):		
• Maker: <u>Boekel</u> Serial Number: <u>1011-24</u> .....	<u>Satisfactory</u>	
• Length Comparator(s) .....	Number Checked: <u>1</u> .....	<u>Satisfactory</u>
• Bar Mold(s) .....	Number Checked: <u>3</u> .....	<u>Satisfactory</u>
<u>Graduates C1005-10</u>		
• Capacity: <u>250 mL</u> CCRL Number: <u>R-1761</u> .....	<u>Satisfactory</u>	
<u>Flow Table C230-14</u>		
• Flow Table(s):		
• Maker: <u>Humboldt</u> .....	<u>Satisfactory</u>	
• Accessory Apparatus .....	<u>Satisfactory</u>	

Inspection Item

Status

Compression Test Apparatus C109-16a and E4-16

- Compression Testing Machine:
  - Maker: Tinius Olsen
  - Serial Number: 222424 Capacity: 60,000 lbf
  - Accuracy of Indication:
    - Range: 60,000 lbf From: 5,000 to 36,000 lbf .. Satisfactory
  - Mechanical Condition ..... Satisfactory
  - Design ..... Satisfactory
  - Verification Records ..... Satisfactory
  - Bearing Blocks ..... Satisfactory
- Cube Molds: Number Checked: 12 ..... Satisfactory
- Tampers ..... Satisfactory

Mix Balance(s) C1005-10

- Maker: Mettler Toledo  
Capacity: 3,100 g CCRL Number: M-1142 ..... Satisfactory

Mechanical Mixing Apparatus C305-14

- Mixer(s):
  - Maker: Hobart Serial Number: 31-1391-318 . Satisfactory
- Accessory Apparatus: ..... Satisfactory

Air Content Apparatus C185-15a

- 400 mL Measure(s) ..... Satisfactory
- Accessory Apparatus ..... Satisfactory

Vicat Apparatus C187-11

- Vicat Apparatus(es):
  - CCRL Number: P-280 ..... Satisfactory
  - CCRL Number: U-2450 ..... Satisfactory
- Vicat Rings: Number Checked: 5 ..... Satisfactory

Density C188-15

- Density Equipment ..... Satisfactory
- Accessory Apparatus ..... Satisfactory

Loss on Ignition C114-15 and C311-13

- Crucible ..... Satisfactory
- Muffle Furnace ..... Satisfactory
- Miscellaneous ..... Satisfactory

Standard Sands C778-13 and E11-16

- Sand Verification ..... Satisfactory
- Sample Splitter ..... Satisfactory
- Sieves ..... Satisfactory

Miscellaneous

- Temperature of Air in Laboratory ..... Satisfactory
- Relative Humidity of Air in Laboratory ..... Satisfactory
- Temperature of Mixing Water ..... Satisfactory
- Miscellaneous Accessory Testing Apparatus ..... Satisfactory
- ASTM Standards ..... Satisfactory



**Procedures**

<u>Test</u>	<u>Method Reference</u>	<u>Technique in Exact Agreement With Standard Practice</u>
Normal Consistency Test .....	C187-11 and C305-14 .....	<u>Yes</u>
Preparation of:		
Autoclave Bars .....	C151-15, C305-14, and C311-13 .....	<u>Yes</u>
Mortar Cubes .....	C109-16a, C305-14, C311-13, and C1437-15 .....	<u>Yes</u>
Testing of Autoclave Bars .....	C151-15 .....	<u>Yes</u>
Testing of Mortar Cubes .....	C109-16a .....	<u>Yes</u>
No. 325 Sieve Fineness Test .....	C311-13 and C430-08 .....	<u>Yes</u>
Moisture Content .....	C311-13 .....	<u>Yes</u>
Loss on Ignition .....	C114-15 and C311-13 .....	<u>Yes</u>
Density .....	C188-15 and C311-13 .....	<u>Yes</u>

## POZZOLAN FOOTNOTE SECTION

### Qualification of Chemical Analysis (C114-15):

(a) Records: Seven Certified Reference Materials (CRMs) were used when performing qualification testing for silicon dioxide, calcium oxide, and sodium oxide. Duplicate tests for sodium oxide did not meet the criteria that at least six of the seven differences between duplicates shall not exceed the limits in Column 2 of Table 1 of C114 and all data shall differ by no more than twice that value as required by Section 5.4.2.2 of C114. Also, when data from the average of duplicate tests for silicon dioxide, calcium oxide, and sodium oxide were compared to the certified concentrations, these analytes did not meet the criteria that at least six of the seven averages for each analyte shall not differ from the limits in Column 3 of Table 1 of C114 and all data shall differ by no more than twice that value as required by Section 5.4.2.3 of C114.

### Curing Facilities (C511-13):

(b) The temperature of the moist storage air and the temperature of the storage water tanks were observed at intervals on May 11, 2017 and found to be as follows:

<u>Time:</u>	<u>Moist Storage Air:</u>	<u>Water Storage #1:</u>	<u>Water Storage #2:</u>	<u>Water Storage #3:</u>
8:30 a.m.	20.8°C	20.6°C	20.6°C	20.3°C
12:00 p.m.	21.0°C	20.1°C	20.1°C	20.0°C
4:00 p.m.	20.6°C	20.3°C	20.3°C	20.1°C

The range specified in C511 is 21.0 to 25.0°C.

## CONCRETE SUMMARY OF FINDINGS

### *Quality System*

<u>Inspection Item</u>	<u>Status</u>
<u>Quality System C1077-16</u>	
• Organization .....	<u>Satisfactory</u>
• Human Resources .....	<u>See footnote (a)</u>
• Operations .....	<u>See footnote (b)</u>
• Quality Assurance .....	<u>Satisfactory</u>
• Equipment .....	<u>Satisfactory</u>

### *Apparatus*

<u>Curing Facilities C511-13</u>	
• Moist Air Storage Facilities .....	<u>Satisfactory</u>
• Water Storage Facilities .....	<u>Satisfactory</u>
<u>Compression Test Apparatus C39-16 and E4-16</u>	
• Compression Testing Machine:	
• Maker: <u>Forney</u>	
• Serial Number: <u>06129</u> Capacity: <u>400,000 lbf</u>	
• Accuracy of Indication:	
• Range: <u>400,000 lbf</u> From: <u>50,000</u> to <u>115,000 lbf</u> ..	<u>Satisfactory</u>
• Mechanical Condition .....	<u>Satisfactory</u>
• Design .....	<u>Satisfactory</u>
• Verification Records .....	<u>Satisfactory</u>
• Bearing Blocks for Cylinders .....	<u>Satisfactory</u>
<u>Molds for Concrete Testing C31-15a and C470-15</u>	
• Cylinder Molds for Four Inch Diameter Specimens .....	<u>Satisfactory</u>
• Beam Molds .....	<u>Satisfactory</u>
<u>Specimen Shipping Containers C31-15a</u>	
• Four Inch Diameter Specimens .....	<u>Satisfactory</u>
<u>Capping Equipment and Materials C617-15</u>	
• Capping Equipment for Four Inch Diameter Specimens .....	<u>Satisfactory</u>
• Capping Material .....	<u>Satisfactory</u>
• Conditions of Caps .....	<u>Satisfactory</u>
<u>Unbonded Caps C1231-15</u>	
• Retaining Rings and Pads for Four Inch Diameter Specimens .....	<u>Satisfactory</u>
• Accessory Apparatus .....	<u>Satisfactory</u>
<u>Slump Cone(s) C143-15a</u> .....	<u>See footnote (c)</u>
<u>Tamping Rod(s) C31-15a</u> .....	<u>Satisfactory</u>
<u>Concrete Vibrators C31-15a, C138-16, and C231-14</u> .....	<u>Satisfactory</u>
<u>Temperature of Concrete C1064-12</u> .....	<u>Satisfactory</u>
<u>Reference Temperature Measuring Devices C511-13 and C1064-12</u>	
• Reference Thermometer(s) - C511 .....	<u>Satisfactory</u>
• Reference Thermometer(s) - C1064 .....	<u>Satisfactory</u>

<u>Inspection Item</u>	<u>Status</u>
<u>Unit Weight Apparatus C138-16</u>	
• Unit Weight Measure(s) .....	<u>Satisfactory</u>
• Accessory Apparatus .....	<u>Satisfactory</u>
• Scale or Balance .....	<u>Satisfactory</u>
<u>Air Content Apparatus (Volumetric) C173-16</u>	
• Air Meter(s) .....	<u>See footnote (d)</u>
• Accessory Apparatus .....	<u>Satisfactory</u>
<u>Air Content Apparatus (Pressure) C231-14</u>	
• Air Meter(s) .....	<u>Satisfactory</u>
• Accessory Apparatus .....	<u>Satisfactory</u>
• Aggregate Correction Factors .....	<u>Satisfactory</u>

**Procedures**

<u>Test</u>	<u>Method Reference</u>	<u>Technique in Exact Agreement With Standard Practice</u>
Slump of Concrete .....	C143-15a .....	<u>Yes</u>
Unit Weight of Concrete .....	C138-16 .....	<u>Yes</u>
Air Content (Volumetric Method) .....	C173-16 .....	<u>Yes</u>
Air Content (Pressure Method) .....	C231-14 .....	<u>Yes</u>
Sampling Freshly Mixed Concrete .....	C172-14a .....	<u>Yes</u>
Measuring Temperature of Concrete .....	C1064-12 .....	<u>Yes</u>
Fabrication of Four Inch Diameter Cylinders ..	C31-15a .....	<u>Yes</u>
Fabrication of Beams .....	C31-15a .....	<u>Yes</u>
Curing of Cylinders .....	C39-16 .....	<u>Yes</u>
Cylinder Measurements .....	C39-16 .....	<u>Yes</u>
Capping of Cylinders .....	C617-15 .....	<u>Yes</u>
Cylinder Checks for Unbonded Caps .....	C1231-15 .....	<u>Yes</u>
Compressive Strength of Cylinders .....	C39-16 .....	<u>Yes</u>

**Additional Test Methods**

	<u>Status</u>
<u>Obtaining and Testing Drilled Cores and Sawed Beams of Concrete C42-13</u>	
• Equipment .....	<u>See footnote (e)</u>
• Procedure .....	<u>Satisfactory</u>
<u>Flexural Strength of Concrete (Using Simple Beam with Third-Point Loading) C78-15a</u>	
• Equipment .....	<u>Satisfactory</u>
• Procedure .....	<u>Satisfactory</u>
<u>Making and Curing Concrete Test Specimens in the Laboratory C192-16a</u>	
• Equipment .....	<u>Satisfactory</u>
• Procedure .....	<u>Satisfactory</u>
<u>Fundamental Transverse, Longitudinal and Torsional Resonant Frequencies of Concrete Specimens C215-14</u>	
• Equipment .....	<u>See footnote (f)</u>
• Procedure .....	<u>Satisfactory</u>

Status

Resistance of Concrete to Rapid Freezing and Thawing C666-15

- Equipment ..... Satisfactory
- Procedure ..... Satisfactory

Measuring Length of Concrete Cores C1542-16a

- Equipment ..... See footnote (g)
- Procedure ..... Satisfactory

## CONCRETE FOOTNOTE SECTION

### Quality System (C1077-16):

(a) Human Resources: It was understood that technician performance evaluations of the ASTM test method C78 were not conducted at the frequency listed in the performance evaluation description.

(b) Operations: The final report included the nominal cylinder diameter rather than the average measured diameter of the cylinders as specified in Section 9.4.7 of C1077 and Section 9.1.2 of C39.

### Slump Cone(s) (C143-15a):

(c) The verification of the slump cones did not include all of the dimensional checks required by Section 5.1.1 of C143.

### Air Content Apparatus (Volumetric) (C173-16):

(d) The volumetric air meter had been verified within the last year; however, records indicated that the verification was not routinely performed at the frequency prescribed in Section 5.1 of C173. Also, records for the volumetric air meter did not include the readings for verifying the graduations throughout the graduated range of the neck as required by Section 5.3.1 of C173.

### Additional Test Methods:

(e) Obtaining and Testing Drilled Cores and Sawed Beams of Concrete (C42-13): With reference to measuring the length of cores, which is required for this test, attention is invited to footnote (g).

(f) Fundamental Transverse, Longitudinal and Torsional Resonant Frequencies of Concrete Specimens (C215-14): The waveform analyzer had a recording capacity of 1024 points of the waveform rather having the ability to record at least 2048 points of the waveform as specified in Section 6.2.3 of C215.

(g) Measuring Length of Concrete Cores (C1542-16a): The caliper used to measure the core was not equipped with offset points as required by Section 5.1.1 of C1542.

## R18 QUALITY SYSTEM SUMMARY OF FINDINGS

<u>Inspection Item</u>	<u>Status</u>
<u>General Criteria</u> .....	<u>Satisfactory</u>
<u>Human Resources</u>	
• Position Descriptions .....	<u>Satisfactory</u>
• Biographical Sketches .....	<u>Satisfactory</u>
• Training .....	<u>Satisfactory</u>
• Performance Evaluations .....	<u>See footnote (a)</u>
<u>Test Methods</u> .....	<u>Satisfactory</u>
<u>Internal Audits</u> .....	<u>Satisfactory</u>
<u>Corrective Action</u> .....	<u>Satisfactory</u>
<u>Sample Management</u> .....	<u>Satisfactory</u>
<u>Records Retention</u> .....	<u>Satisfactory</u>
<u>Test Records and Reports</u> .....	<u>Satisfactory</u>
<u>Assuring the Quality of Results</u> .....	<u>Satisfactory</u>
<u>Equipment Verifications</u>	
• List .....	<u>Satisfactory</u>
• Procedures .....	<u>Satisfactory</u>
• Records .....	<u>Satisfactory</u>
<u>Equipment Maintenance</u>	
• List .....	<u>Satisfactory</u>
• Procedures .....	<u>Satisfactory</u>
• Records .....	<u>Satisfactory</u>

Note: This R18 quality system review was performed in conjunction with other quality system reviews previously listed in this report, attention is invited to those sections.

## **R18 QUALITY SYSTEM FOOTNOTE SECTION**

### Quality System (R18-16):

(a) Human Resources: It was understood that technician performance evaluations of the AASHTO test method T97 were not conducted at the frequency listed in the performance evaluation description.



## CLOSURE

This inspection was performed by the writer. While the work was in progress, many of the details covered by this report were discussed with laboratory personnel. At the conclusion of the inspection the special work sheets, on which all observations were recorded, were made available for review by members of the laboratory staff, and all of the entries thereon were discussed in detail.

Identification of the testing equipment used by the CCRL inspector during the inspection can be found on the CCRL website at [www.ccrl.us](http://www.ccrl.us) under the heading of traceability.

It is recommended that this report be compared with the report of the preceding inspection which was made in October 2014. For further reference the CCRL laboratory number is 35.

This report does not approve, certify or accredit this laboratory. Publicizing the inspection without full disclosure of this report is not permitted.

Cement and Concrete Reference Laboratory



Angela N. Windland  
Inspector