



**END VIEW**  
(Type BT-72 P.C.B.)

**HALF ELEVATION AT ABUTMENT**

**HALF ELEVATION AT PIER**

Information shown on this sheet is applicable only to the standard bridge cross-section with 40' Clear Roadway, 8" Deck Slab and 4 Beams at 11'-4" spacing. Any deviation requires custom design and details with an appropriate Dead Load Deflection Diagram.

**PRESTRESSED CONCRETE BEAM NOTES**

**COMPRESSIVE STRENGTH**  
Provide concrete with a compressive strength of 6,300 p.s.i. at transfer of prestress and 9,000 p.s.i. at 28 days.

**STRAND TYPE**  
Provide low-relaxation strands having a nominal diameter of 0.6" with ultimate tensile strength of 270 k.s.i.

**LFD OPERATING RATING - HS 41.1**  
The Operating Rating shown is based on a nominal strength using only strands that are bonded for the full length of the beam. All partially bonded strands are neglected in strength computations.

① Provide Elastomeric Pad with a 50 durometer hardness and consisting of a single layer 7/8" thick x 3'-6" wide x 5'-10 1/2" long. Extend pad 1/2" beyond the end of the beam as shown.

APPROVED BY BRIDGE ENGINEER *Scott J. Smith* DATE *4/2/10*

OKLAHOMA DEPT. OF TRANSPORTATION  
BRIDGE STANDARD (ENGLISH)  
**TYPE BT-72 P.C. BEAM DETAILS**  
105' SPAN  
**INTEGRAL (SHEET 1 OF 2)**

2009 SPECIFICATIONS | B40-I-PCB-BT-105-1 | 02E | B-120E