

**Acceptance Form for Reinforcing Steel on Non-SiteManager Projects**

Revised: 3/9/2006 - Page 1 of 1

**Identify the Project and Material:**

Project: \_\_\_\_\_ Residency: \_\_\_\_\_ Date:

Product Category: Reinforcing Steel (723) \*Material: \_\_\_\_\_

\*Product Name: \_\_\_\_\_ \*Manufacturer: \_\_\_\_\_

Intended Use: \_\_\_\_\_

\*List Material, Product Name and Manufacturer in the same manner as they appear on the Approved Products List.

**Check All That Apply:**

**Yes No**

- 1. Inspected for Reinforcing Steel Fabricator fixed shipping tags or labels
- 2. Product Name is listed as an Approved Product (Unexpired & F.A. Method 5005)
- 3. Shipment(s) included deformed bars
- 4. Proper deformed bar mill markings were observed (Record mill and P/S Code in Remarks)
- 5. Improper deformed bar mill markings were observed
- 6. Shipment(s) included epoxy coated steel
- 7. Epoxy coating was inspected and is acceptable

The "Yes" must be checked for 1. and 2. above If "No" is checked for 1. or 2. check "Fail" for Final Test Results. Material must meet those requirements to be accepted using this form.

If "Yes" is checked for 3. above, "Yes" must also be checked for 4.

If "Yes" is checked for 5. above, submit 2 ea. 24" representative samples to Materials Division Lab along with a copy of this Form and record that fact in Remarks below. (sample to include mill mark if possible)

If "Yes" is checked for 6. above, "Yes" must also be checked for 7.

If Final Test Results are "Fail" for any reason, explain details such as represented quantities in Remarks below.

Remarks:  None

---

---

---

---

**Indicate Final Test Results:**

- Pass
- Fail

Reviewed by: \_\_\_\_\_

Construction Residency