

THE DETAILS SHOWN ON THIS SHEET ARE FOR STORM SEWER APPLICATIONS ONLY AND ARE NOT INTENDED FOR SANITARY SEWER APPLICATIONS.

TO INCLUDE A REDUCED RISER, DEPTH OF MANHOLE

MUST BE A MINIMUM OF 52 INCHES.

## **GENERAL NOTES**

- 1. ALL CONSTRUCTION AND MATERIAL REQUIREMENTS SHALL BE IN ACCORDANCE WITH THE 2009 ODOT STANDARD SPECIFICATIONS.
- FOR DETAILS OF FRAME AND COVER, SEE CURRENT VERSION OF ROADWAY STANDARD MFC-4. PRICE BID OF MANHOLE SHALL INCLUDE PAYMENT FOR THESE ITEMS AND ALL OTHER ITEMS AND LABOR, NECESSARY TO COMPLETE THE INSTALLATION, PRICE BID OF ADDITIONAL DEPTH SHALL INCLUDE PAYMENT FOR ALL MATERIAL AND LABOR PERTAINING ONLY TO THE ADDITIONAL DEPTH, NECESSARY TO COMPLETE ITS INSTALLATION.
- 3. ROUND MANHOLES MAY BE SUBSTITUTED PER THE MANUFACTURER'S
- 4. THERE SHALL BE A MINIMUM DISTANCE OF 6" BETWEEN AN OPENING AND ANY JOINT.
- 5. PROVIDE LIFTING DEVICES IN CONFORMANCE WITH THE MANUFACTURER'S
- PROVIDE GRADE 60 REINFORCING STEEL CONFORMING TO ASTM A615 OR EQUIVALENT AREA OF WELDED WIRE REINFORCING CONFORMING
- 7. PROVIDE A MINIMUM CLEAR COVER OF 11/2" TO REINFORCING STEEL.
- 8. WALLS OR SLABS WITH A THICKNESS OF 8" OR GREATER REQUIRE A SECONDARY LAYER OF REINFORCING STEEL. PROVIDE AN AREA OF REINFORCING STEEL EQUAL TO 0.11 SQ. IN.<sup>2</sup>/ FT EACH WAY IN THE SECONDARY LAYER.
- 9. DESIGN TONGUE AND GROOVE JOINTS FOR FULL CLOSURE ON RISER SHOULDERS, CONICAL TOPS, AND FLAT SLABS. MINIMUM SPIGOT DEPTH
- 10. MAXIMUM OPENING SHALL BE 4" LARGER THAN OUTSIDE PIPE DIAMETER. REFER TO ROADWAY DESIGN STANDARD PMD-1 FOR PIPE CONNECTION ΜΔΤΕΡΙΔΙ
- 11. SEAL TONGUE AND GROOVE JOINTS WITH PREFORMED OR BULK MASTIC IN CONFORMANCE WITH THE MANUFACTURER'S RECOMMENDATIONS. TONGUE AND GROOVE JOINTS MAY BE GROUTED NO MORE THAN 1" BETWEEN EACH SECTIONS OR 1/2 THE JOINT DEPTH, WHICHEVER IS GREATER. JOINT SEALING SHALL BE INCLUDED IN THE COST OF THE
- 12. DO NOT GROUT RUBBER GASKET JOINTS WITHOUT THE MANUFACTURER'S RECOMMENDATIONS.
- 13. THE FOUNDATION SHALL BE STABILIZED OR REMOVED AND REPLACED WITH FIRM AND STABLE FOUNDATION MATERIAL. A MINIMUM 3" THICK LEVELING COURSE SHALL BE PROVIDED BELOW THE BASE AREA OF THE MANHOLE AND EXTEND 6" BEYOND THE BASE AREA. THE LEVELING COURSE SHALL BE CONSTRUCTED WITH AGGREGATE BASE TYPE A. COSTS ASSOCIATED WITH THE FOUNDATION AND LEVELING COURSES SHALL BE INCLUDED IN THE PRICE BID OF THE MANHOLE.
- 14. OPENINGS IN FLAT SLAB TOPS SHALL BE ADDITIONALLY REINFORCED WITH A MINIMUM OF 0.20 SQ. IN. OF STEEL AT 90 DEGREES.
- 15. REFER TO PROJECT PLAN SHEETS FOR NUMBER, LOCATION, AND SIZE OF
- LÉVÉLÍNG COURSE 16. FLEXURAL REINFORCING STEEL SHALL NOT EXCEED SPACING OF 9" CENTER SHALL BE 3" MIN. TO CENTER TO CENTER.
  - 17. SEE CURRENT VERSION OF ROADWAY STANDARD PRM-1 FOR DIMENSIONS AND REINFORCING REQUIREMENTS FOR PRECAST CONCRETE ROUND MANHOLES, WITH AND WITHOUT ROUND REDUCED RISER SECTIONS.
  - 18. THE ENGINEER MAY SPECIFY THE USE OF STEPS OR LADDERS AND SHALL CONFORM TO ASTM C478.
  - THE ORIENTATION OF THE SPIGOT IS SHOWN FOR INFORMATIONAL PURPOSES ONLY AND IS AT THE DISCRETION OF THE MANUFACTURER.

BASIS OF PAYMENT		
ITEM NO.	ITEM	UNIT
611(A)	PRECAST CONC SQ 4' WIDE MANHOLE	EACH
611(A)	PRECAST CONC SQ 5' WIDE MANHOLE	EACH
611(A)	PRECAST CONC SQ 6' WIDE MANHOLE	EACH
611(B)	ADD'L DEPTH PRECAST SQ 4' MANHOLE	VF
611(B)	ADD'L DEPTH PRECAST SQ 5' MANHOLE	VF
611(B)	ADD'L DEPTH PRECAST SQ 6' MANHOLE	VF

APPROVED BY ROADWAY ENGINE PRECAST SQUARE MANHOLE

ROADWAY STANDARD

OKLAHOMA DEPARTMENT OF TRANSPORTATION 2009 SPECIFICATIONS

PSM-1

R-45