
	TΔ	BLE A - SCI	HEDULE OF P	IPE SAFETY	GR/	ATES	ent.	
		SIDE DRAIN		CROSS DRAIN				
C. E. T. TYPE	REINF. CONC., STEEL OR ALUMINUM ROUND PIPE	REINF. CONC. ARCH PIPE	REINF. CONC. ELLIPTICAL PIPE (RISE x SPAN)	STEEL OR ALUMINUM ARCH PIPE	NO. OF GRATES	GRATE LENGTH L(SD)	NO. OF GRATES	GRATE LENGTH L(CD)
Α4	18"				2	36"	NONE	
		22" x 13"	14" x 23"	21" x 15"	2	42"	NONE	
				24" x 18"	2	45"	NONE	
B4	24"				3	45"	NONE	
		28" x 18"	19" x 30"		2	48"	. 1	10'-9"
				28" x 20"	2	48"	NONE	
		36" x 22"	22" x 34"		3	54"	1	12'-0"
				35" x 24"	3	54"	1	12'-6"
			24" x 38"		3 ,	57"	.1.,	12'-6"
C4	30"				5	50"	NONE	
		43" x 26"			3	64"	1	13'-6"
				42" x 29"	3	64"	. 1	14'-3"
			29" x 45"		3	64"	1	14'-3"
		51" x 31"			4	70"	1	15'-3"
				49" x 33"	4	70"	1	15'-9"
			34" x 53"		4	73"	11	15'-9"
D4	36"		()		4	54"	1	16'-6"
	42"				5	61"	1	18'-9"
		58" x 36"	38" x 60"	57" x 38"	5	78"	1	17'-3"
		65" x 40"			5	86"	2	18'-0"
				64" x 43"	5	84"	2	19'-0"
	48"				6	68"	1	20'-9"
E4			43" x 68"		5	90"	2	19'-0"
		73" x 45"		71" x 47"	6	92"	2	20'-6"
			48" x 76"		6	99"	2	20'-9"



SECTION B - B

LIMITS OF PAYMENT


FOR PIPE CULVERT

	TABLE B - SCHEDULE OF DIMENSIONS											
C.E.T.		® WIDTH		LENOTH	LIEIOLIE		(R)		REINF. BAR LENGTH			
TYPE	LENGTH A	WIDTH B	WIDTH B	LENGTH C	HEIGHT H	HEIGHT K	CONC.	CONC.	R H-BARS		S-BARS	
Α4	10'-4"	5'- 6"	6'- 2"	5'- 8"	21"	9"	1.70	2.00	5'- 2"	5'-10"	12'- 4"	
B4	12'-4"	6'- 0"	7'- 2"	6'- 0"	22"	14"	2.00	2.60	5'- 8"	6'-10"	15'- 4"	
C4	15'-9"	6'- 6"	8'- 5"	7'- 4"	26"	20"	2.85	3.95	6'- 2"	8'- 1"	19'- 6"	
D4	19'-3"	7'- 6"	9'- 6"	8'- 0"	28"	27"	3.50	5.05	7'- 2"	9'- 2"	21'- 6"	
E4	20'-8"	8'- 0"	10'- 4"	8'- 8"	30"	30"	4.05	5.75	7'- 8"	10'- 0"	23'- 4"	

(R) ROUND SHAPE CULVERT OPTIONS

ARCH SHAPE CULVERT OPTIONS

(E) HORIZONTAL ELLIPSE SHAPE CULVERT OPTIONS



6" (MIN.) **CROSS DRAINS** SIDE DRAINS ANCHOR END DETAIL PIPE GRATE MEMBERS


5/8" DIA


5/8" x 1" SLOT


GENERAL NOTES

- ALL CONSTRUCTION AND MATERIAL REQUIREMENTS SHALL BE IN ACCORDANCE WITH THE 2019 ODOT STANDARD SPECIFICATIONS.
- QUANTITIES SHOWN IN TABLE B ARE FOR ONE END ONLY. CLASS A CONCRETE SHALL CONFORM TO THE MINIMUM REQUIREMENTS OF SECTION 509 OF THE ODOT SPECIFICATIONS
- TYPES A4 THROUGH E4 END TREATMENTS, AS SHOWN IN TABLE B. MAY BE USED WITH ANY AASHTO DESIGNATED METAL, ALUMINUM AND CONCRETE PIPE SIZES, AS SHOWN IN TABLE A. END TREATMENT QUANTITIES ARE BASED ON METAL PIPE DIMENSIONS, NO PIPE WALL THICKNESS AND SMALLEST LISTED CULVERT ROUND OR ARCH WITHIN SAME
- COAT THE FIELD OR SHOP CUT EDGES OF THE METAL PIPE CULVERT WITH TWO COATS OF COLD GALVANIZATION. COAT THE FIELD OR SHOP CUT EDGES OF THE CONCRETE PIPE CULVERT WITH CONCRETE OR AN APPROVED CORROSION INHIBITOR. IF THE PIPE CULVERT IS CUT AFTER THE CONSTRUCTION OF THE CULVERT END TREATMENT, THE CONTRACTOR SHALL ALLOW SUFFICIENT TIME FOR THE PROPER CURING OF THE CONCRETE. INCLUDE THE COST OF CUTTING AND COATING IN THE PRICE BID FOR THE METAL AND/OR CONCRETE PIPE CULVERT.
- ALL SIZES OF CULVERT PIPE WILL BE CUT ON 1 TO 4 SLOPE. PIPE FOR SAFETY GRATES SHALL BE 3" x 7.58 LBS./FT. STANDARD WEIGHT STEEL PIPE, SCHEDULE 40. IT SHALL BE FURNISHED GALVANIZED, PLAIN END AND SHALL MEET THE MINIMUM REQUIREMENTS OF ASTM A53 (HYDROSTATIC TESTS MAY BE WAIVED) OR ASTM F1083. COST OF GRATES TO BE INCLUDED IN PRICE BID FOR THE CULVERT END
- ANY GALVANIZED AREA(S) OF METAL PIPE DISTRESSED DURING THE POST FABRICATION AND/OR HANDLING PROCESS SHALL BE COATED WITH AN APPROVED ZINC-RICH
- REINFORCING STEEL AND PIPE GRATE GUIDES SHALL BE NO. 4 DEFORMED BARS, COST OF STEEL SHALL BE INCLUDED IN PRICE BID FOR THE CULVERT END TREATMENT.
- CRITERIA FOR USE OF PIPE SAFETY GRATE MEMBERS:
- ALL SIDE DRAIN AND MULTIPLE PIPE INSTALLATIONS WITHIN THE CLEAR ZONE. ALL CROSS DRAIN INSTALLATIONS WITH A CULVERT SPAN OF 30" OR LARGER WITHIN THE CLEAR ZONE.
- (C) ALL INSTALLATIONS OUTSIDE THE CLEAR ZONE WHERE HAZARD POTENTIAL IS HIGH BASED ON TRAFFIC DIRECTION, SPEED, VOLUME, AND SIZE OF CULVERT. NOTE: ANALYZE HYDRAULIC PERFORMANCE AT VARYING DEGREES OF CLOGGING AND APPLY RISK ASSESSMENT BEFORE USING GRATES.
- ANCHOR END OF PIPE GRATE MEMBERS SHALL BE HELD IN PLACE WITH A 1/2" x 5 1/2" GALVANIZED BOLT, NUT AND WASHER. THREADS, 13/4" (NOM.) SHALL REMAIN EXPOSED FOR INSTALLING GRATE, WASHER AND NUT. ALL BOLTS, NUTS AND WASHERS SHALL CONFORM TO ASTM A307 WITH COST TO BE INCLUDED IN THE PRICE BID FOR THE CULVERT END TREATMENT.
- FOR TOTAL QUANTITY OF EXTRA DEPTH TOE WALL, MULTIPLY WIDTH B (TABLE B)
 TIMES 0.0185 FOR EACH FOOT OF DEPTH OF TOE WALL REQUIRED. PAYMENT TO BE INCLUDED IN PRICE BID FOR THE CULVERT END TREATMENT.

PRECAST CULVERT END TREATMENTS OR OTHER ALTERNATIVE DESIGNS MAY BE USED IF APPROPRIATE DRAWINGS ARE SUBMITTED TO AND APPROVED BY THE ENGINEER.







■ CET ORIENTATION AND SAFETY GRATE REQUIREMENTS SHALL BE SPECIFIED ON THE SUMMARY OF DRAINAGE STRUCTURES.


> APPROVED BY ROADWAY ENGINEER: DATE: 6/30/22

ROADWAY DESIGN DIVISION STANDARD CULVERT END TREATMENT

SINGLE PIPE INSTALLATION OKLAHOMA 1TO 4 SAFETY SLOPE OKLAHOMA Transportation

2019 SPECIFICATIONS CET4S-4

2 R-30



- GRATED

VARIES

S-BAR 2EA.-NO.4REINF. STEEL

Z-BAR 2 EA. - NO. 4 REINF. STEEL

R=2" = 50